

## J1939-MOT-P2

**Device:** See supported devices.

**Protocol:** J1939-MOT-P2

**Protocol Version:** 1

Copyright © 2025 MOTORTECH GmbH		For internal use only	
Computer created. No manual inspection.		Revision	60321
<a href="http://svn.rnd.motortech.local/development/projects/P920850/trunk/900-Software/930-Design">//svn.rnd.motortech.local/development/projects/P920850/trunk/900-Software/930-Design</a>			
Date	2025-11-25 11:07	Status	Approved

## Contents

<b>1</b>	<b>Introduction</b>	<b>2</b>
1.1	Purpose of the Document . . . . .	2
1.2	Validity of the Document . . . . .	2
1.3	Supported Devices . . . . .	2
1.4	Applicable Documents . . . . .	2
1.5	Definitions of Terms and Abbreviations . . . . .	2
1.6	Notation Notes . . . . .	2
<b>2</b>	<b>J1939 Communication</b>	<b>3</b>
2.1	Address Configuration . . . . .	3
2.2	Bit/Byte Numbering . . . . .	3
2.3	Data Ranges . . . . .	3
2.3.1	Transmitted Signal Ranges . . . . .	3
2.3.2	Transmitted Values for Discrete Parameters . . . . .	4
2.3.3	Transmitted Values for Control Commands . . . . .	4
<b>3</b>	<b>Used PGNs</b>	<b>5</b>
3.1	Commands 61307 . . . . .	5
3.2	Position 65530 . . . . .	5
<b>I</b>	<b>Revision History</b>	<b>7</b>
<b>II</b>	<b>Used Tools</b>	<b>8</b>
<b>III</b>	<b>Copyright</b>	<b>9</b>

# 1 Introduction

## 1.1 Purpose of the Document

This document describes the proprietary J1939 PGNs used to communicate with this device.

## 1.2 Validity of the Document

No constraints defined.

## 1.3 Supported Devices

The following devices are supported in the specified versions.

Device	from	to
ITB-DC	2.2.0	.-
VariStep3	1.2.0	.-

## 1.4 Applicable Documents

- SAE J1939-21, revised April 2001
- SAE J1939-71, revised Jun2006

## 1.5 Definitions of Terms and Abbreviations

ITB-DC	<b>I</b> ntegrated <b>T</b> hrottle <b>B</b> ody – <b>D</b> irect <b>C</b> ontrol
LSB	<b>L</b> east <b>S</b> ignificant <b>B</b> it
MSB	<b>M</b> ost <b>S</b> ignificant <b>B</b> it
MICT	<b>M</b> OTORTECH <b>I</b> ntegrated <b>C</b> onfiguration <b>T</b> ool
PGN	<b>P</b> arameter <b>G</b> roup <b>N</b> umber
PF	<b>P</b> DU <b>F</b> ormat
PS	<b>P</b> DU <b>S</b> pecific
SPN	<b>S</b> uspect <b>P</b> arameter <b>N</b> umber

## 1.6 Notation Notes

The data page is zero, unless explicitly specified otherwise.

## 2 J1939 Communication

### 2.1 Address Configuration

The device source address must be configured via MICT, address claiming is not supported.

- device with even sources address will be treated as device 0.
- device with odd source address will be treated as device 1.

Therefore only two devices, one with even and the other one with odd source address, are supported.

### 2.2 Bit/Byte Numbering

Unlike SAE J1939-71, bits and bytes in this document are numbered from 7 (MSB) to 0 (LSB) and not from 8 (MSB) to 1 (LSB).

Byte 0								Byte 1								Byte 3								Byte 4							
7	6	5	4	3	2	1	0	7	6	5	4	3	2	1	0	7	6	5	4	3	2	1	0	7	6	5	4	3	2	1	0

Byte 4								Byte 5								Byte 6								Byte 7							
7	6	5	4	3	2	1	0	7	6	5	4	3	2	1	0	7	6	5	4	3	2	1	0	7	6	5	4	3	2	1	0

### 2.3 Data Ranges

According to J1939-71 the transmitted data ranges are defined as follows:

#### 2.3.1 Transmitted Signal Ranges

Common representation of integer values:

Range Name	1 byte	2 byte	4 byte	ASCII
Valid Signal	0x00 to 0xFA	0x0000 to 0xFAFF	0x00000000 to 0xFAFFFFFFF	Latin-1 0x20 to 0x7E
Parameter specific indicator	0xFB	0xFB00 to 0xFBFF	0xFB000000 to 0xFBFFFFFFF	—
Reserved range for future indicator bits	0xFC to 0xFD	0xFC00 to 0xFDFF	0xFC000000 to 0xFDFFFFFFF	—
Error indicator	0xFE	0xFExx	0xFExxxxxx	—
Not available or not requested	0xFF	0xFFxx	0xFFxxxxxx	—

The character set used for text is a restricted Latin-1 (ISO 8859-1) character set. The string end is marked by '\*'.

### 2.3.2 Transmitted Values for Discrete Parameters

Two bits are usually used for this purpose.

Range Name	Transmitted Value
Disabled (off, passive, etc.)	0b00
Enabled (on, active, etc.)	0b01
Error indicator	0b10
Not available or not installed	0b11

### 2.3.3 Transmitted Values for Control Commands

Two bits are usually used for this purpose.

Range Name	Transmitted Value
Command to disable function (turn off, etc.)	0b00
Command to enable function (turn on, etc.)	0b01
Reserved	0b10
Don't care/take no action (leave function as is)	0b11

### 3 Used PGNs

The following chapters list and describe the PGNs used to communicate with the device. The Rx/Tx prefix of the PGN name indicates the direction as seen from the device.

Rx Received by the device.

Tx Transmitted by device.

The data page is always 0.

The device must be configured via MICT to use the fieldbus as the external target input. Control Setup → Selection → Input → Field bus

Please change the preset PGNs.

#### 3.1 Commands 61307

Description	Value
Direction	Rx/Receive
Data length in bytes	2
Default Priority	6
Parameter Group Number	61307 / 0x0.EF.7B

This PGN is located in proprietary area A. This means that the lower byte contains the destination address.

In order for the PGN to be accepted, the source address of the device must be set to 123 (0x7B), as this is handled in accordance with J1939-21. Or the destination address in the transmitter can be adjusted.

Byte(.Bit)	Size [Bit]	SPN	Name	Value	Unit and Scaling
0	16		Position Demand in percent	0x0000 - 0x9C40	Value = raw * 0.0025 + 0 [%]

#### 3.2 Position 65530

Description	Value
Direction	Tx/Send
Data length in bytes	8
Default Priority	6
Transmission repetition rate	100 [ms]
Parameter Group Number	65530 / 0x0FFFA

This PGN is located in proprietary area B. For details see J1939-21.

If the identifier 0x18FFFA7B is to be sent, the source address must be set to 123 (0x7B) and the Transmit PGN to 0xFFFA in the MICT.

Byte(.Bit)	Size [Bit]	SPN	Name	Value	Unit and Scaling
0	16		Current position		Value = raw * 0.0025 [%]
2	16		Target position		Value = raw * 0.0025 [%]
4	8		Current Temperature	0x00 - 0xFA	Value = raw - 40.0 [°C]
5	8		Overall Control Status		N/A
6	16		Specific Diagnostic Indication		N/A

## I Revision History

Date	Name	Comment	Rev.
2025-06-11	Zabe, Volker	Init	
2025-11-24	Zabe, Volker	Approved	1



## II Used Tools

Tool	Version
MUSE-Link	0.2
MUSE	1.0
MUSE-J1939	0.2
MUSE-Link	0.2
MUSE-Latex	0.3

### III Copyright

**English:**

The reproduction, distribution and utilization of this document as well as the communication of its contents to others without explicit authorization is prohibited. Offenders will be held liable for the payment of damages. All rights reserved in the event of the grant of a patent or utility model.

The project management owns a current version of this document where it can be requested. All changes will be forwarded to the undersigned mentioned above.

**Deutsch:**

Weitergabe sowie Vervielfältigung dieser Unterlage, ihre Verwertung und Mitteilung ihres Inhalts ist nicht gestattet, außer es wird ausdrücklich zugestanden. Zuwiderhandlungen verpflichten zu Schadenersatz. Alle Rechte für den Fall der Patenterteilung oder Gebrauchsmustereintragung vorbehalten.

Dieses Dokument liegt in seiner aktuellen Version bei der Projektleitung und kann von dort angefordert werden. Alle Änderungen werden an oben genannte Unterzeichner weitergeleitet.